

#	Sample	Analysis	Matrix	Analyte	Laboratory	Units	MDL	MRL	Rep Limit	Result	Qualifiers
1	S2HT1	524THM	Drinking Water	Bromodichloromethane	Metiri Group - Geneva	ug/L	0.26		1	0.26	7.9
1	S2HT1	524THM	Drinking Water	Bromoform	Metiri Group - Geneva	ug/L	0.27		1	0.27	0.62 J
1	S2HT1	524THM	Drinking Water	Chloroform	Metiri Group - Geneva	ug/L	0.22		1	0.22	10
1	S2HT1	524THM	Drinking Water	Dibromochloromethane	Metiri Group - Geneva	ug/L	0.2		1	0.2	5
1	S2HT1	524THM Total	Drinking Water	Total Trihalomethanes (TTHMS)	Metiri Group - Geneva	ug/L	0.96		4	0.96	24
1	S2HT1	552	Drinking Water	Bromoacetic acid	Metiri Group - Geneva	ug/L	0.32		1	0.32 ND	U
1	S2HT1	552	Drinking Water	Chloroacetic acid	Metiri Group - Geneva	ug/L	0.45		2	0.45	1.2 J
1	S2HT1	552	Drinking Water	Dibromoacetic acid	Metiri Group - Geneva	ug/L	0.36		1	0.36	1.2
1	S2HT1	552	Drinking Water	Dichloroacetic acid [2C]	Metiri Group - Geneva	ug/L	0.31		1	0.31	6
1	S2HT1	552	Drinking Water	Trichloroacetic acid	Metiri Group - Geneva	ug/L	0.33		1	0.33	5.2
1	S2HT1	552 Total	Drinking Water	Total Haloacetic Acids (HAA5)	Metiri Group - Geneva	ug/L	0.45		2	0.45	14
2	S2HT2	524THM	Drinking Water	Bromodichloromethane	Metiri Group - Geneva	ug/L	0.26		1	0.26	7.5
2	S2HT2	524THM	Drinking Water	Bromoform	Metiri Group - Geneva	ug/L	0.27		1	0.27	0.58 J
2	S2HT2	524THM	Drinking Water	Chloroform	Metiri Group - Geneva	ug/L	0.22		1	0.22	9.3
2	S2HT2	524THM	Drinking Water	Dibromochloromethane	Metiri Group - Geneva	ug/L	0.2		1	0.2	4.7
2	S2HT2	524THM Total	Drinking Water	Total Trihalomethanes (TTHMS)	Metiri Group - Geneva	ug/L	0.96		4	0.96	22
2	S2HT2	552	Drinking Water	Bromoacetic acid	Metiri Group - Geneva	ug/L	0.32		1	0.32 ND	U
2	S2HT2	552	Drinking Water	Chloroacetic acid	Metiri Group - Geneva	ug/L	0.45		2	0.45	1.2 J
2	S2HT2	552	Drinking Water	Dibromoacetic acid	Metiri Group - Geneva	ug/L	0.36		1	0.36	1.1
2	S2HT2	552	Drinking Water	Dichloroacetic acid [2C]	Metiri Group - Geneva	ug/L	0.31		1	0.31	5.3
2	S2HT2	552	Drinking Water	Trichloroacetic acid	Metiri Group - Geneva	ug/L	0.33		1	0.33	4.5
2	S2HT2	552 Total	Drinking Water	Total Haloacetic Acids (HAA5)	Metiri Group - Geneva	ug/L	0.45		2	0.45	12